

Test Report No. SDFS2210006514OS Date: Nov.07, 2022 Page 1 of 3

CHANGZHOU JINUO DECORATIVE MATERIAL CO.,LTD NO.318 XUANJIA TOWN YAOGUAN TOWN ECONOMIC DEVELOPMENT DISTRICT,CHANGZHOU CITY

Sample Description : MFB FLOOR Color : YELLOW

Thickness : 8mm

The above data and information was / were submitted and identified on behalf of the client. SGS is not responsible for the authenticity, integrity and results of the data and information and / or the validity of the conclusion.

SGS Ref. No. : SHFS2209000562OS, CAN22-224937

Sample Receiving Date : Oct.13, 2022

Test Performing Date : Oct.21, 2022 to Nov.04, 2022

Test Requested	Result
HJ 571-2010 (Clause 5.3.1) - Total Volatile Compounds(TVOC)	See Results

Signed for and on behalf of Shunde Branch SGS-CSTC Co., Ltd.

Ada



Ada Liu Approved signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction document. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 83071443, or email: CN.Doccheck@sgs.com

| 作, Fulding European Industrial Park, No.1 Shurine South Road, Wilsta Section, Dalarg Town, Shuruke Fosten, Guargdong, China 528333 t (86—757)22805888 f (86—757)22805858 www.sgs.group.com.cn 中国・广东・保山市順徳区大良街道办事处五沙版和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86—757)22805888 f (86—757)22805858 sgs.china@sgs.com



Test Report No. SDFS2210006514OS Date: Nov.07, 2022 Page 2 of 3

Test Results:

Test Part Description:

SGS Sample ID Description

CAN22-224937.001 White solid material board with light taupe surface

Remarks:

(1) 1 mg/kg = 0.0001%

(2) MDL = Method Detection Limit

(3) ND = Not Detected (< MDL)

(4) "-" = Not Regulated

HJ 571-2010 - Total Volatile Compounds(TVOC)

Test Method: With reference to HJ571-2010.

Testing was performed by Environmental Chamber (1m³), followed by sampling using Tenax-TA

and absorption tube with water, analysis using Thermodesorption System with Gas

Chromatography Mass Spectrometry (TDS-GC-MS) and UV-Vis.

To determine quantitative volatile organic compounds.

Test Item(s)	<u>Unit</u>	MDL	<u>001</u>
Test condition			
Chamber Volume	m³	-	1.0
Testing Temperature	$^{\circ}$ C	-	23±0.5
Testing Humidity	RH%	-	45±3
Air Exchange Rate	1/h	-	1±0.05
Sample Loading	m^2/m^3	-	1±0.02
Tenax Sampling Flow	mL/min	-	200
Tenax Sampling Time	min	-	25
Tenax Sampling Volume	L	-	5
Sampling Flow	mL/min	-	2000
Sampling Time	min	-	60
Sampling Volume	L	-	120
TVOC (C6~C16)	mg/(m²∙h)	0.002	ND

Remark:

1. mg/(m²· h) = milligram per square metre and hour

Unless otherwise stated, the decision rule for conformity reporting is based on Binary Statement for Simple Acceptance Rule (w = 0) stated in ILAC-G8:09/2019.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN. Doccheck@sas.com

| 作, Fulding European Industrial Park, No.1 Shurine South Road, Wilsta Section, Dalarg Town, Shuruke Fosten, Guargdong, China 528333 t (86—757)22805888 f (86—757)22805858 www.sgs.group.com.cn 中国・广东・保山市順徳区大良街道办事处五沙版和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86—757)22805888 f (86—757)22805858 sgs.china@sgs.com



Test Report

No. SDFS2210006514OS

Date: Nov.07, 2022

Page 3 of 3

Sample photo:



Remark: This test was subcontracted to SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch.

End of Report



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-en-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN. Doccheck@sas.com

IR/「Building European Industrial Park,No.15 Numbe South Road, Wisha Seaton, Dalaray Town, Shunde, Fosten, Guargdong, China 528333 t (86—757)22805888 f (86—757)22805858 www.sgs.group.com.cn 中国・广东・佛山市順徳区大良街道办事处五沙順和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86—757)22805888 f (86—757)22805858 sgs.china@sgs.com